



Jason M. Lajoie  
FIRE CHIEF

North Hampton  
**FIRE & RESCUE**

235 ATLANTIC AVENUE  
NORTH HAMPTON, NEW HAMPSHIRE 03862  
www.northhampton-nh.gov Bus. Ph. (603) 964-5500



The following information and documentation must be provided with the application before permit for Installation/Alteration of a Sprinkler System can be issued:

Design, installation, and testing shall conform to NFPA 1, NFPA 13, NFPA 13D, and NFPA 13R, NFPA 24, and NFPA 25.

**One (1) set of complete plans. “Complete” indicates that all of the following are present:**

1. Letter from designer indicating that plans meet all requirements of NH State Fire Code SAF-C-6000 as adopted and all local ordinances of the Town of North Hampton.
2. Hydraulic calculations.
3. Specification sheets for sprinklers, piping, and other devices.
4. For backflow prevention, a letter will be submitted to the Fire Department showing approval of the type and location of devices by the local Water Company.

**IMPORTANT NOTE:** Depending upon the scope of work, a review may be required by a Fire Protection Engineer (FPE) prior to acceptance by the Fire Department. Reviews by NH registered professional engineers with a specialty in Fire Protection **only** are acceptable. Any deviations from the approved plan must be submitted to the FPE of record for review, then stamped and submitted to the Fire Department prior to final testing.