



Jason M. Lajoie  
FIRE CHIEF

North Hampton  
**FIRE & RESCUE**  
235 ATLANTIC AVENUE  
NORTH HAMPTON, NEW HAMPSHIRE 03862  
www.northhampton-nh.gov Bus. Ph. (603) 964-5500



## **SPRINKLER PERMIT APPLICATION**

Application is hereby made for the **installation** or **alteration** of a Sprinkler System. The North Hampton Fire Department requires certain information prior to installation. Design, installation, and testing shall conform to NFPA 1, NFPA 13, NFPA 13D, NFPA 13R, NFPA 24, and NFPA 25 (editions as adopted by NH State Fire Code, SAF-C-6000) and local ordinances.

### **INFORMATION REQUIRED:**

**Submission of one (1) set of COMPLETE plans.** "Complete" indicated that the plans and applications shall be accompanied by the following:

- Letter from the designer reflecting that plans meet all requirements of NH State Fire Code SAF-C-6000 as adopted as well as Town of North Hampton Local ordinances.
- All information regarding the system:
  - Hydraulic calculations.
  - Specification sheets for sprinklers, piping, and all other devices.
  - For backflow prevention, a letter will be submitted to the Fire Department showing approval of the type and location of the devices by local Water Company.

**IMPORTANT NOTE:** A review shall be required by a Fire Protection Engineer (FPE) before acceptance by the Fire Department. Reviews by NH registered professional engineers with a specialty in Fire Protection only are acceptable. All documents must be reviewed and stamped by the FPE to be considered a complete application.

**Approved plans must be on file with the Fire Department and a permit must be issued prior to start of installation. Failure to obtain a permit before start of installation may result in fines.**

Plans that have been approved by the bureau will be stamped and a copy will be given to the installer. The Fire Department shall be notified and review any deviations from the approved plan prior to final testing. Prior to final acceptance, a signed Contractor's and Materials Test Certificate for above-ground piping shall be submitted to the Fire Department.

**All inspections require a minimum of 48 hours advance notice by installed. A Fire Official shall witness any required flow, air, and/or hydrostatic tests.**

Permit Fee: According to current fee schedule.

**Checks made payable to: The Town of North Hampton.**

**THIS IS NOT A PERMIT**

Date Of Application: \_\_\_\_\_

Property Name/Address: \_\_\_\_\_

Sprinkler Company Name/Phone: \_\_\_\_\_

Installer Name: \_\_\_\_\_